



Approval of the Trademark Trevira CS®

ADO Goldkante GmbH & Co. KG
Zimmersmühlenweg 14-18
61440 Oberursel
Germany

Application No.:	220750.1
Date of issue:	28.11.2022
Valid until:	14.10.2027
Article name:	3144
End use:	Curtains
Square weight (g/m²):	86
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The article 3144 has been tested under the Trevira trademark application no. 220750 in col. beige and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

The article meets the requirements for class 1 according to EN 13773.

Trevira GmbH
(This document is valid without signature.)